Well tag id: AGA625
33/02E/26F

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy -- Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. G1-00103C
Permit No.

(1) OWNER: Name DAVIS LANDING OWNERS ASSOC. Address 3086 N. MT BAKER CIRCLE, OAK HARBOR

(2) LOCATION OF WELL: County ISLAND SE ¼ NW ¼ Sec 26 T. 33 N. R 2E W.
Bearing and distance from section or subdivision corner (80' N & 354' W OF CTR. OF SEC. 26)

(3) PROPOSED USE: Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one) 5
New well [X] Method: Dug [ ] Bored [ ]
Deepened [ ] Cable [X] Driven [ ]
Reconditioned [ ] Rotary [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 117 ft. Depth of completed well 117 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from 0 ft. to 112 ft.
Threaded [ ] " Diam. from ft. to ft.
Welded [X] " Diam. from ft. to ft.

Perforations: Yes [ ] No [X]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [X] No [ ] Johnson
Manufacturer's Name
Type STAINLESS Model No
Diam. 6 Slot size 10 from 112 ft. to 117 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name (GOULDS) (10ES 074J2)
Type: SUB H.P. (3/4)

(8) WATER LEVELS: Land-surface elevation above mean sea level 160 ± ft.
Static level 98 ft. below top of well Date APR 96
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [X] No [ ] If yes, by whom? BOBS Pumps
Yield: 15 gal./min. with 8 ft. drawdown after 4 hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 10 gal./min. with 6 ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG:
Formation: Describe by color, character, size of material and structure, a show thickness of aquifers and the kind and nature of the material in ea stratum penetrated, with at least one entry for each change of formatic

MATERIAL	FROM	TO
HARD PAN	0	12
GRAVELY HARD	12	45
SANDY HARD PAN	45	66
DIRTY DRY SAND	66	100
WATER SAND	100	117
X FINE SAND (DRAWER)	117±	
(15 GPM MAX RECOMMEN		
(156lm)		
(130' MSL)		

RECEIVED
MAR 14 2008
DEPT OF ECOLOGY

Work started APR 96 Completed APR 11 19

WELL DRILLER'S STATEMENT:
This well was drilled under my jurisdiction and this repo true to the best of my knowledge and belief.

NAME WHIDBEY WELL DRILLERS (Person, firm, or corporation) (Type or print)
Address OAK HARBOR, WN
[Signed] (Well Driller)
License No. 129 Date APR 19

(USE ADDITIONAL SHEETS IF NECESSARY)

33/020/26F

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No. G1-00103C
Permit No.

(1) OWNER: Name DAVIS LANDING OWNERS ASSOC. Address 3086 N. MT BAKER CIRCLE, OAK HARBOR 98277

(2) LOCATION OF WELL: County ISLAND SE ¼ NW ¼ Sec 26 T. 33 N., R. 2E W.M.
Bearing and distance from section or subdivision corner (80' N & 354' W OF CTR. OF SEC. 26)

(3) PROPOSED USE: Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one) 5
New well [X] Method: Dug [ ] Bored [ ]
Deepened [ ] Cable [X] Driven [ ]
Reconditioned [ ] Rotary [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 117 ft. Depth of completed well 117 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from 0 ft. to 112 ft.
Threaded [ ] " Diam. from ft. to ft.
Welded [X] " Diam. from ft. to ft.

Perforations: Yes [ ] No [X]
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [X] No [ ] Johnson
Manufacturer's Name
Type STAINLESS Model No.
Diam. 6 Slot size .10 from 112 ft. to 117 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name (GOULDS) (10ET07412)
Type: Sub H.P. (3/4)

(8) WATER LEVELS: Land-surface elevation above mean sea level 160 ± ft.
Static level 98 ft. below top of well Date APR 96
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [X] No [ ] If yes, by whom? BOBS Pumps
Yield: 15 gal./min. with 8 ft. drawdown after 4 hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test 10 gal./min. with 6 ft. drawdown after 4 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
HARD PAN	0	12
GRAVELY HARD	12	45
SANDY HARD PAN	45	66
DIRTY DRY SAND	66	100
WATER SAND	100	117
X FINE SAND (DRAWER)	117 ±	

(15 GPM MAX RECOMMENDED)

(15GPM)

(130' MSL)

Work started APR, 19 96 Completed APR 11, 19 96

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY WELL DRILLERS (Person, firm, or corporation) (Type or print)
Address OAK HARBOR, WN
[Signed] Dennis Foker (Well Driller)
License No. 129 Date APR, 19 96

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20

WASHINGTON STATE DEPARTMENT OF ECOLOGY

Well Tagging Form

Unique Well Tag No: BCB781

RECORD VERIFICATION (check ✓one)

☑ Well Report available (please attach this form to the well report and submit it to the Ecology Regional Office near you).

If a well report is not available, please complete a "Water Well Report for an Existing Well" form. This form is available at Ecology's headquarters office. **Do not use this form for wells that do not have a Water Well Report.**

WELL OWNERSHIP, IF DIFFERENT FROM WELL REPORT

First Name: Davis Landing Owners' Association Last Name:

Street Address: 3036 Mount Baker Circle

City: Oak Harbor State: WA 98277

Well #5, DoH Source S06

LOCATION OF WELL, IF DIFFERENT FROM WELL REPORT

Well Address: Parcel S6450-00-00013-0 Green Road and Strawberry Point Road

City: Oak Harbor County: Island

T. 33 N. R. 2 E W.M. Sec. 26 SE ¼ of the NW

Latitude 48 19.09837"

Longitude 122 31.17331"

Elevation at land surface 160 (feet/meters) *(circle one)*

RECEIVED

JAN 04 2013

DEPT OF ECOLOGY NWRO WR

SEE BACK SIDE OF PAGE...

WELL CHARACTERISTICS

Location of Well identification Tag: Stapped to well casing (inside wooden "dog house" enclosure on wooded lot west of the reservoir

D	C (Well)	B	A
E	F	G	H
M	L	K	J
N	P	Q	R

Scale 1:24,000 (1" = 2,000')

Indicate the location of the well within the Section by drawing a dot at that point

SECTION 26

COMMENTS:

This well tag replaces previous tag AGA625 that was apparently lost when the submersible pump was recently replaced. The previous tag was attached with a plastic "zip-tie". New tag BCB782

This is Davis Landing Well #4 (DoH Source 505)